

OUR PEOPLE | OUR POWER

ASSET MANAGEMENT PLAN UPDATE

2017



TABLE OF CONTENTS

INTRODUCTION

SECTION 1	Summary of the Plan
SECTION 2	Background & Objectives
SECTION 3	Service Levels
SECTION 4	Network Development Plans
SECTION 5	Life Cycle Asset Management
SECTION 6	Non-Network Development Maintenance & Renewal
SECTION 7	Risk Management
SECTION 8	Evaluation of Performance
SECTION 9	Capability to Deliver
SECTION 10	Schedules

This Asset Management Plan (AMP) Update is available for public disclosure and applies for the period 1 April 2017 to 31 March 2027.

© CENTRALINES LIMITED 2017



1. INTRODUCTION

This Asset Management Plan (AMP) Update has been completed pursuant to clause 2.6 of the Electricity Distribution Information Disclosure Determination 2012. It provides details of material changes to critical aspects of the AMP disclosed by Centralines in March 2016, and should be read as supplementary to that document. For the purpose of this AMP Update, material changes are defined as significant deviations from the 2016 AMP with respect to how Centralines manages its assets. Significant process changes, the adoption of new tools and techniques and adding, removing or rescheduling projects in excess of \$250,000 are considered material changes.

In order to ensure the latest information is available, various sections and tables which are considered non-material have also been updated and refreshed and are included in this AMP Update.

The purpose of this AMP Update is to ensure that the requirements of the AMP continues to be met in years where it is not compulsory for a full AMP to be disclosed. Centralines will next disclose a full AMP in 2018.

SECTION 1 SUMMARY OF THE PLAN

SECTION 1 SUMMARY OF THE PLAN 1-1

CONTENTS

1.	SUMMARY OF THE PLAN	1-2
1.2	Introduction to this Document.....	1-2

1-2 SECTION 1 SUMMARY OF THE PLAN

1. SUMMARY OF THE PLAN

1.2 Introduction to this Document

The Centralines Limited AMP Update is a comprehensive explanation of how the company will develop and manage the lifecycle of its electricity distribution assets over the period 2017 – 2027 to achieve its Asset Management Objectives.

SECTION 2 BACKGROUND & OBJECTIVES



SECTION 2 BACKGROUND & OBJECTIVES 2-1

CONTENTS

2.	BACKGROUND AND OBJECTIVES	2-2
2.3	Purpose of the Asset Management Plan.....	2-2
2.3.2	Objectives of Asset Management and Planning Processes	2-2
2.5	Date of Director Approval	2-3
Table 2-1: Asset Management Objectives.....		2-2

2-2 SECTION 2 BACKGROUND & OBJECTIVES

2. BACKGROUND AND OBJECTIVES

2.3 Purpose of the Asset Management Plan

2.3.2 Objectives of Asset Management and Planning Processes

To ensure there is a clear *line of sight* through the Asset Management System (AMS), Centralines' Asset Management Objectives are informed directly by the Organisational Strategic Plan and the Asset Management Policy. There are three objectives:

1. **Health and Safety Performance:** Centralines' objective is to achieve an incident free workplace by creating a culture where each person truly believes that "Safety First" is a core value and that working safely is part of all employees' everyday activities. Centralines is committed to the Health and Safety of its Employees, Contractors, Customers and Community.
2. **Customer Service Performance:** Deliver great customer service through provision of a reliable and resilient network at a reasonable price.
3. **Cost and Efficiency Performance:** Improve the efficiency and effectiveness of asset management practices through innovative network and energy solutions.

The current measures that enable Centralines to monitor and improve performance in relation to these objectives are provided in Table 2-1. More detail on Centralines' Customer Service Performance objective and associated measures is provided in Section 3: Service Levels.

Asset Management Objective	Measure	Current Target (2017/18)
Health and Safety Performance	Accidents causing harm to a member of the public or significant damage to public property	0
	Serious harm or lost-time injury to employees or contractors	0
	Injuries to employees or contractors requiring medical treatment	< 2
Customer Service Performance	Surveyed Customer Satisfaction with delivery of customer works	> 95%
	Average annual number of minutes a customer is without supply (SAIDI)	99 – 119
	Average annual number of supply interruptions a customer experiences (SAIFI)	2.9 – 3.5
	Revenue per ICP (nominal)	<\$1,644
	Restoration of Supply for unplanned interruptions	See Section 3
Cost and Efficiency Performance	Forward work planning horizon at a project level provided to contracting services providers	≥ 3 years rolling
	Operating expenditure per ICP (nominal)	<\$425
	Faults per 100km of network	< 6.4

Table 2-1: Asset Management Objectives

SECTION 2 BACKGROUND & OBJECTIVES 2-3

2.5 Date of Director Approval

The AMP Update was approved by Centralines' Board of Directors on 29 March 2017.

SECTION 3 SERVICE LEVELS



SECTION 3 SERVICE LEVELS 3-1

CONTENTS

3.	SERVICE LEVELS.....	3-2
3.3	Serviced Level Framework.....	3-2
Table 3-1: Service Level Framework.....		3-2

3-2 SECTION 3 SERVICE LEVELS

3. SERVICE LEVELS

3.3 Serviced Level Framework

Asset Management Objective	Service Level	Unit/Type	Service Level Targets				
			2016/17	2017/18	2018/19	2019/20-20/21	2021/22-26/27
Health and Safety Performance	Accidents causing harm to a member of the public	Number of Accidents	0	0	0	0	0
	Serious harm or lost-time injury to employees or contractors	Number of Injuries	0	0	0	0	0
	Injuries to employees or contractors requiring medical treatment	Number of Injuries	< 2	< 2	< 2	< 2	< 2
Customer Service Performance	Surveyed Customer Satisfaction	Percentage of Satisfied Customers	> 95%	> 95%	> 95%	> 95%	> 95%
	SAIDI	Minutes	98.80 – 119.07	98.80 – 119.07	98.80 – 119.07	98.80 – 119.07	98.80 – 119.07
	SAIFI	Interruptions	2.84 – 3.52	2.84 – 3.52	2.84 – 3.52	2.84 – 3.52	2.84 – 3.52
	Revenue per ICP	\$ (nominal)	\$1,588	\$1,644	1,665	\$1,686-\$1,707	\$1728-1,818
	Restoration of Supply for unplanned interruptions	Urban	≤ 20 events ≥ 3 hours	≤ 20 events ≥ 3 hours	≤ 20 events ≥ 3 hours	≤ 20 events ≥ 3 hours	≤ 20 events ≥ 3 hours
		Rural	≤ 10 events ≥ 6 hours	≤ 10 events ≥ 6 hours	≤ 10 events ≥ 6 hours	≤ 10 events ≥ 6 hours	≤ 10 events ≥ 6 hours
		Remote Rural	≤ 5 events ≥ 12 hours	≤ 5 events ≥ 12 hours	≤ 5 events ≥ 12 hours	≤ 5 events ≥ 12 hours	≤ 5 events ≥ 12 hours
Cost and Efficiency Performance	Forward work planning horizon	Years	≥ 1	≥ 2 rolling	≥ 3 rolling	≥ 3 rolling	≥ 3 rolling
	Operating expenditure per ICP	\$ (nominal)	\$447	\$425	\$428	\$432	\$461
	Faults per 100km of network	Total	6.4	6.4	6.4	6.4	6.4

Table 3-1: Service Level Framework

SECTION 4 NETWORK DEVELOPMENT PLANS



SECTION 4 NETWORK DEVELOPMENT PLANNING 4-1

CONTENTS

4. Network Development Plans	4-2
4.11 Output - Network Development Programme	4-2
4.11.1 Projects for 2017/18 to 2026/27	4-2
4.11.2 Non-Material Projects for 2017/18	4-3
4.11.3 Material Projects for 2018/19 to 2021/22	4-8
4.11.4 Material Projects for 2022/23 to 2026/27	4-10
Table 4-13: Projects for 2017/18 to 2026/27	4-3
Table 4-14: Non-Material Projects for 2017/18	4-7
Table 4-15: Material Projects for 2018/19-to 2021/22	4-9
Table 4-16: Material Projects for 2022/23 to 2026/27	4-10

4-2 SECTION 4 NETWORK DEVELOPMENT PLANNING

4. NETWORK DEVELOPMENT PLANS

4.11 Output - Network Development Programme

Projects greater than \$250,000 are considered material and will be discussed to a greater level of detail. For completeness all projects (material and non-material) planned for 2017/18 and all material projects proposed for 2018/19-2026/27 have been included.

Customer-driven projects where a contract is not in place are not included.

Details of projects for the ten-year planning period are outlined below.

4.11.1 Projects for 2017/18 to 2026/27

There are no material projects planned for the 2017/18 year.

A summary table describing the confirmed non-material projects for the 2017/18 year is included in Section 4.11.2.

#	Constraint	Category	Cost	Section
2017/18 Non-Material				
1	Reliability and restoration response on rural feeders	Quality of Supply	\$210k	4.11.2
2	11kV capacity constraint, Waipukurau CBD	System Growth	\$40k	4.11.2
3	400V Voltage constraint, Ruataniwha Street, Waipawa CBD	Quality of Supply	\$80k	4.11.2
4	Wilder Road Substation - Preparations for substation upgrade	Other Reliability, Safety and Environment	\$100k	4.11.2
5	Power quality (voltage) on rural feeders	Quality of Supply	\$110k	4.11.2
6	Online Temperature Monitoring – Waipukurau Zone Substation power transformers	Other Reliability, Safety and Environment	\$25k	4.11.2
7	Two pole transformer replacement B4/8, Waverley Street, Waipawa	Other Reliability, Safety and Environment	\$100k	4.11.2
8	11kV Relocation – Porangahau Bridge	Other Reliability, Safety and Environment	\$120k	4.11.2
9	Load Control Fibre Link	Quality of Supply	\$10k	4.11.2
10	Waipawa GXP ION meter installation	Quality of Supply	\$35k	4.11.2

SECTION 4 NETWORK DEVELOPMENT PLANNING 4-3

2018/19 to 2021/22 Material				
11	Reliability and restoration response on rural feeders	Quality of Supply	\$830k	4.11.3
12	Wilder Road Substation - Substation upgrade	Other Reliability, Safety and Environment	\$300k	4.11.3
13	Voltage Regulation on rural feeders	Quality of Supply	\$500k	4.11.3
14	Voltage fluctuation constraint at Takapau Zone Substation	Other Reliability, Safety and Environment	\$250k	4.11.3
15	Communications Link, Transpower GXP to Takapau Substation	Other Reliability, Safety and Environment	\$625k	4.11.3
2022/23 to 2026/27 Material				
16	Reliability and restoration response on rural feeders	Quality of Supply	\$950k	4.11.4
17	Voltage Regulation on rural feeders	Quality of Supply	\$500k	4.11.4

Table 4-13: Projects for 2017/18 to 2026/27

4.11.2 Non-Material Projects for 2017/18

#	Constraint	Constraint Description	Options	Cost	Preferred Solution
1	Reliability and restoration constraints on rural feeders	<p>Rural feeders often have many assets in complicated configurations spread over a large area. The means that response and restoration times can be significant, affecting customer service and overall network performance.</p> <p>Feeders have been assessed and prioritised with the following feeders scheduled for implementation in 2017/18.</p> <ul style="list-style-type: none"> • Feeder 1 – OngaOnga-Ashley Clinton area • Feeder 83 – Omakere-Elsthorpe area 	<ul style="list-style-type: none"> • Preferred: Network – Automate key switches • Network – Install ground fault neutraliser • Non-Network - Reconfigure network • Do nothing 	\$210k	<p>The preferred solution is the lowest cost solution that will resolve the constraint.</p> <p>It will typically result in reducing outage times to a few seconds for approximately half the customers affected by any given outage.</p> <p>The switches will also provide additional network information to improve modelling tools going forward.</p> <p>Installing a ground fault neutraliser will be very effective for certain types of faults but ineffective for others.</p> <p>Reconfiguring the network will ultimately require replacement of other assets that will cost more than the preferred solution to achieve the same result.</p>

4-4 SECTION 4 NETWORK DEVELOPMENT PLANNING

#	Constraint	Constraint Description	Options	Cost	Preferred Solution
		<ul style="list-style-type: none"> Feeder 18 – Waipukurau South Feeder 46 – Herbertville area 			<p>Doing nothing does not resolve the constraint.</p> <p>The network solution in this instance costs less than the non-network solution.</p>
2	11kV capacity constraint, Waipukurau CBD	There is a 50m section of cable in the backbone of the Waipukurau CBD feeder that modelling has indicated is too small for the load it is carrying under certain network configurations. Removing this constraint will reduce the risk of an outage to the Waipukurau CBD should a fault occur.	<ul style="list-style-type: none"> Preferred: Network – Increase existing capacity Non–Network Transfer load Reduce load Do nothing 	\$40k	<p>The preferred option is the lowest cost option that resolves the constraint.</p> <p>There are no non-network options that would resolve the constraint. Load transfer creates a constraint on the adjacent circuits and the amount of load reduction required to remove the constraint cannot be reliably or practically achieved.</p>
3	400V Voltage constraint, Ruataniwha Street, Waipawa	An issue has been identified where, under certain loading conditions, the voltage will be outside the regulated limits for some customers in the area. This has been confirmed using monitoring equipment in 2016.	<ul style="list-style-type: none"> Preferred: Network – Additional 400V circuit Network – Install additional transformer Increase existing circuit capacity Non–Network Transfer load Reduce load Do nothing 	\$80k	<p>The preferred option is the lowest cost option that resolves the constraint.</p> <p>It will remove the constraint and increase operational flexibility in the area.</p> <p>Installing an additional transformer would remove the constraint and offer flexibility but there are no 11kV circuits in the affected area to enable this option.</p> <p>Increasing existing capacity will require replacement of existing support structures as well as additional structures. This will cost the same as the preferred option but cause greater inconvenience during construction and not offer the additional operational flexibility.</p> <p>There are no non-network options that would resolve the constraint. Load transfer creates a constraint on the adjacent circuits and the amount of load reduction required to remove the constraint cannot be reliably or practically achieved.</p>

SECTION 4 NETWORK DEVELOPMENT PLANNING 4-5

#	Constraint	Constraint Description	Options	Cost	Preferred Solution
4	Wilder Road Substation - Preparations for substation upgrade	<p>Wilder Road substation is located on leased land and does not meet the latest standards regarding seismic strength and clearances.</p> <p>Part of the options evaluation has identified that the lowest cost construction solution will require additional land.</p> <p>The work planned for 2017/18 involves land owner negotiation with provision for formalising the extended lease area before proceeding with more detailed design work for the reconstruction.</p>	<ul style="list-style-type: none"> • Preferred: Network – Purchase Additional Land • Network – extend leased area • Non–Network Retain existing footprint • Remove substation 	\$100k	<p>The preferred solution ensures the asset meets current standards while providing certainty for the site in future.</p> <p>Extending the leased area, while meeting standards, does not provide long term certainty.</p> <p>Retaining the existing footprint does not eliminate the potential hazards from any event that may occur at the site.</p> <p>Removing or relocating the substation would require significant expenditure on other assets to ensure supply is maintained to the customers.</p>
5	Power quality (voltage) on rural feeders	<p>Altering loads and load use patterns have created voltage constraints on some rural feeders. Modelling indicates that there are further potential issues on the network.</p> <p>Feeders identified and prioritised are:</p> <ul style="list-style-type: none"> • Feeder 1 – OngaOnga-Ashley Clinton • Feeder 2 – Wakarara-Tikokino • Feeder 18 – Waipukurau South • Feeder 19 – Hatuma-Wanstead • Feeder 45 – Porangahau-Wallingford • Feeder 46 – Herbertville • Feeder 75 – Paget Road-Burnside • Feeder 83 – Omakere-Elsthorpe 	<ul style="list-style-type: none"> • Preferred: Non-Network – Monitor • Network – Install voltage regulators • Increase conductor size • Non–Network Transfer load • Reduce load 	\$110k	<p>Installing monitoring equipment on remote distribution transformers will verify and/or quantify any voltage constraints This will optimise any necessary investment and provide increased data for making operational decisions.</p> <p>Installing voltage regulators will resolve any issues but may not be necessary for all constraints.</p> <p>Increasing conductor size will resolve most issues but would be optimally carried out as part of the lifecycle of the asset.</p> <p>Transferring load may resolve some issues but will require better data to endure constraints are not created elsewhere on the network.</p> <p>Reducing load or shifting the timing to the degree necessary is not practical at this stage. It may be an option if developing constraints are detected early enough through monitoring.</p>

4-6 SECTION 4 NETWORK DEVELOPMENT PLANNING

#	Constraint	Constraint Description	Options	Cost	Preferred Solution
6	Waipawa Zone Transformer Condition	Takapau's Zone Substation transformers were manufactured in 1977. Better knowledge of asset condition will enable the optimal scheduling for end of life replacement when required.	<ul style="list-style-type: none"> • Preferred: Non-Network – Online monitoring • Network – Replace now • Non-Network Increased testing • Transfer load • Reduce load • Fault level reduction 	\$25k	<p>Online monitoring will provide better information to the Control Centre, as well as providing trending and behavioural characteristics for the assets to determine asset health and enable optimal scheduling for end of life replacement.</p> <p>Replacing the assets now may be unnecessary and deferral by anything more than two years will pay back the investment in the monitoring equipment.</p> <p>Increased, invasive testing is disruptive and may hasten the deterioration of asset condition.</p> <p>Transferring or otherwise reducing the load only inhibits part of the asset aging process as a large portion of asset deterioration is caused by pass through faults. Fault level reduction would address this aspect but further monitoring would still be required in either case to adequately determine asset condition.</p>
7	Two pole transformer replacement B4/8 Waverley Street, Waipawa	Two pole transformer structures present a seismic risk due to a combination of a high centre of gravity and asset aging.	<ul style="list-style-type: none"> • Preferred: Network – Replace with pad mounted transformer • Network – Replace existing structure • Replace with two smaller single pole transformers • Non-Network Remove and transfer load 	\$100k	<p>Replacing with a modern equivalent pad mounted transformer reduces the public hazard and improves the aesthetics at a site which is adjacent to a park in central Waipawa.</p> <p>Adjacent transformers are too far away to support load whilst maintaining voltage on an ongoing basis without increasing capacity and conductor size.</p>

SECTION 4 NETWORK DEVELOPMENT PLANNING 4-7

#	Constraint	Constraint Description	Options	Cost	Preferred Solution
8	11kV Relocation, Porangahau Bridge	Porangahau is a holiday settlement and the bridge giving road access is often used for fishing. There have been multiple instances of fishing lines contacting the power lines which creates a public safety hazard and a risk to the supply in the area.	<ul style="list-style-type: none"> • Preferred: Network – Relocate line away from bridge • Network – Replace line with cable • Non–Network Install barrier • Signage 	\$120k	<p>Relocating the line presents the lowest cost solution that will remove the hazard.</p> <p>Replacing the line with cable will also remove the hazard but cost more and present an additional hazard where the cable is attached to the bridge.</p> <p>Installing a barrier will result in an additional hazard between pedestrians and vehicles as well as create longer term maintenance issues.</p> <p>Signage has already been installed but has not been effective.</p>
9	Load Control Fibre Link	Load management and streetlight control are currently reliant on a radio link. This presents a risk if the radio link fails. A more direct and secure link would provide better security for this key function.	<ul style="list-style-type: none"> • Preferred: Network – Install a fibre optic link between the Waipawa GXP and the Waipukurau signal injection plant • Network – Install a backup radio link • Do nothing 	\$10k	<p>The most costly portion of the preferred option (the fibre optic cable) is already installed and in service. The cost allocated is just to allow a connection into the existing cable.</p> <p>A second radio link would be more expensive and still subject to some of the risks associated with the existing radio link.</p> <p>Doing nothing presents a risk of failure that remedying will exceed the cost of the preferred option.</p>
10	Waipawa GXP Ion meter installation	The existing Ion meter is no longer supported by the supplier and does not have the functionality of other meters currently in use.	<ul style="list-style-type: none"> • Preferred: Network – Replace the meter • Do nothing 	\$35k	<p>Replacing the meter will ensure continued support from the supplier as well as providing extra functionality including power quality measurement and fault detection.</p> <p>Doing nothing means there is a risk of replacement delay at an inconvenient time when a failure occurs.</p>

Table 4-14: Non-Material Projects for 2017/18

4-8 SECTION 4 NETWORK DEVELOPMENT PLANNING

4.11.3 Material Projects for 2018/19 to 2021/22

#	Constraint	Constraint Description	Options	Cost	Solution
11	Reliability and restoration constraints on rural feeders	Rural feeders often have many assets in complicated configurations spread over a large area. This means that response and restoration times can be significant affecting customer service and overall network performance.	<ul style="list-style-type: none"> • Preferred: Network – Automate key switches • Network – Install ground fault neutraliser • Non-Network - Reconfigure network • Do nothing 	\$830k	<p>Feeders have been assessed and prioritised with the following feeders scheduled for implementation in 2018/19 - 2021/22.</p> <ul style="list-style-type: none"> • Feeder 4 – Burnside - Pukeora area • Feeder 74 – Takapau - Otawhao • Feeder 75 – Paget Road area • Feeder 76 – Maharakeke • Feeder 18 – Waipukurau South • Feeder 19 – Hatuma - Wanstead • Feeder 1 – OngaOnga – Ashley Clinton area • Feeder 46 – Herbertville • Feeder 86 – Otane • Feeder 83 – Elsthorpe • Feeder 88 – Pourerere
12	Wilder Road Substation upgrade	<p>Wilder Road Substation is located on leased land and does not meet existing standards regarding seismic strength and safety distances.</p> <p>Part of the options evaluation has identified that the lowest cost construction solution will require additional land.</p> <p>The work planned (assuming successful land owner negotiations in 2017/18) will include seismic strengthening, improved oil spill retention, increased electrical safety distances and more flexible operating connectivity.</p>	<ul style="list-style-type: none"> • Preferred: Network – Upgrade substation • Network – relocated substation • Non-Network Retain existing footprint • Remove substation 	\$300k	<p>The preferred solution ensures the asset meets current standards while providing certainty for the site in future.</p> <p>Relocating the substation will cost significantly more than rebuilding and may result in a suboptimal location for supplying the local area.</p> <p>Retaining the existing footprint does not eliminate the potential hazards from any event that may occur at the site.</p> <p>Removing or relocating the substation would require significant expenditure on other assets to ensure supply is maintained to the customers.</p>

SECTION 4 NETWORK DEVELOPMENT PLANNING 4-9

#	Constraint	Constraint Description	Options	Cost	Solution
13	Power quality (voltage) on rural feeders	Altering loads and load use patterns have created voltage constraints on some rural feeders. Modelling indicates that there are further potential issues on the network.	<ul style="list-style-type: none"> • Preferred: Non - Network – Monitor • Network – Install voltage regulators • Increase conductor size • Non–Network Transfer load • Reduce load 	\$500k	<p>Installing monitoring equipment on remote distribution transformers will verify and/or quantify any voltage constraints This will optimise any necessary investment and provide increased data for making operational decisions.</p> <p>Installing voltage regulators will resolve any issues but may not be necessary for all constraints.</p> <p>Increasing conductor size will resolve most issues but would be optimally carried out as part of the lifecycle of the asset.</p> <p>Transferring load may resolve some issues but will require better data to endure constraints are not created elsewhere on the network.</p> <p>Reducing load or shifting the timing to the degree necessary is not practical at this stage. It may be an option if developing constraints are detected early enough through monitoring.</p> <p>The amount budgeted is provisional, subject to the results obtained by monitoring equipment and assumes constraints are identified and some mitigation is required.</p>
14	Voltage fluctuation constraint at Takapau Zone Substation	Operation of the protection at Takapau Zone Substation results in voltage dips under fault conditions.	<ul style="list-style-type: none"> • Preferred: Network Install 33kV feeder protection relay and 33kV voltage transformers • Do nothing 	\$250k	<p>The preferred option is the lowest cost option that resolves the constraint.</p> <p>It will enable fast power system fault clearance and unitised protection.</p> <p>There are no non-network options that would resolve the constraint.</p>
15	Protection operation speed at Takapau Zone Substation	The upgraded protection at Takapau Zone Substation will require improved communications as extra data is used to operate the scheme.	<ul style="list-style-type: none"> • Preferred: Network Install Fibre communications link to Transpower GXP • Do nothing 	\$625k	<p>The preferred option is the lowest cost option that resolves the constraint.</p> <p>It will enable fast power system fault clearance and unitised protection.</p> <p>There are no non-network options that would resolve the constraint.</p>

Table 4-15: Material Projects for 2018/19 to 2021/22

4-10 SECTION 4 NETWORK DEVELOPMENT PLANNING

4.11.4 Material Projects for 2022/23 to 2026/27

All projects for 2022 to 2027 are in the initial identification stage. High level solutions have been identified and costs have been estimated for the solutions identified as preferred, however all constraints and possible solutions will be reviewed during annual planning to confirm the constraints still exist and, the timing of the constraints have not changed. More detailed investigation into the solutions will be undertaken closer to the planned commencement of the project.

Network development works for this period will be dependent on the energy demand growth experienced on the network. Most energy demand growth on the Centralines' network for the planning period is expected to be driven by customer-driven works and are not included here.

Customers have indicated that the trade-off between reliability and price are appropriate and as a result it is suggested that further investment will generally be limited to relatively minor upgrades to the worst-performing feeders to ensure that customers currently experiencing poor reliability on feeders are progressively upgraded.

Safety-driven upgrades are expected to remain relatively minor during the planning period, due to the relatively robust nature of the network, age profiles of the assets and the relatively high levels of investment in renewals and replacements that are discussed in Section 5.

#	Title	Constraint Description	Options	Cost
16	Reliability constraints on Rural feeders	Rural feeders often have many assets in complicated configurations spread over a large area. The means that response and restoration times can be significant affecting customer service and overall network performance.	<ul style="list-style-type: none"> • Preferred: Network – Automate key switches • Network – Install ground fault neutraliser • Non-Network - Reconfigure network • Do nothing 	\$950k
17	Power quality (voltage) on Rural feeders	<p>Altering loads and load use patterns have created voltage constraints on some rural feeders. Modelling indicates that there are further potential issues on the network.</p> <p>The amount budgeted is provisional, subject to the results obtained by monitoring equipment and assumes constraints are identified and some mitigation is required.</p>	<ul style="list-style-type: none"> • Preferred: Non - Network – Monitor • Network – Install voltage regulators • Increase conductor size • Non–Network Transfer load • Reduce load 	\$500k

Table 4-16: Material Projects for 2022/23 to 2026/27

SECTION 5 LIFE CYCLE ASSET MANAGEMENT

SECTION 5 LIFE CYCLE ASSET MANAGEMENT 5-1

CONTENTS

5.	LIFECYCLE ASSET MANAGEMENT PLANNING	5-2
5.33	Renewal Project List 2017-2018	5-2
Table 5-74: Renewal Project List 2017-2018		5-2

5-2 SECTION 5 LIFE CYCLE ASSET MANAGEMENT

5. LIFECYCLE ASSET MANAGEMENT PLANNING

5.33 Renewal Project List 2017-2018

Asset Category	Project Description	Project Budget (\$000)
Sub-transmission Lines	Wilder Road, 33kV Line Refurbishment, Stage 6	150
Sub-transmission Lines	Wilder Road, 33kV Line Refurbishment, Stage 5 (carry over from 2016/17)	120
Distribution and LV Lines	Replace Mainline 11kV Copper Conductor Adjacent to Primary School Between Poles 907753 and 908434 in Nancy Street, Takapau	125
Distribution Substations, Transformers	Replace Transformer C4/203	65
Distribution and LV Lines	Pole Replacements following feeder Inspections	300
Distribution and LV Lines	Church Street 11kV Replacement	40
Distribution and LV Lines	Provisional sum for unplanned and reactive replacements	250

Table 5-1: Renewal Project List 2017-2018

SECTION 6 NON-NETWORK DEVELOPMENT MAINTENANCE & RENEWAL



SECTION 6 NON-NETWORK DEVELOPMENT M & R 6-1

CONTENTS

6.	NON-NETWORK DEVELOPMENT MAINTENANCE & RENEWAL	6-2
6.2	Property	6-2
6.2.3	Material Capital Expenditure Projects Planned for the Next Five Years	6-2

Table 6-1:	Material Capital Expenditure Projects Planned for the Next Five Years.....	6-2
------------	--	-----

6-2 SECTION 6 NON-NETWORK DEVELOPMENT M & R

6. NON-NETWORK DEVELOPMENT MAINTENANCE & RENEWAL

6.2 Property

6.2.3 *Material Capital Expenditure Projects Planned for the Next Five Years*

The following table details a proposed capital project.

Project	Description
Earthquake Strengthening	Assessments have been completed on both the Centralines' Peel Street depot and Coughlan Road storage yard buildings. Some mitigation is required with work scheduled to be carried out in 2017/18. The storage yard buildings will be completed as part of a network project as strengthening work is also required on the Waipukurau Substation building which is on the same site.

Table 6-1: *Material Capital Expenditure Projects Planned for the Next Five Years*

SECTION 7 RISK MANAGEMENT



SECTION 7 RISK MANAGEMENT 7-1

CONTENTS

7.	RISK MANAGEMENT.....	7-2
7.7	Emergency Response and Contingency Plans.....	7-2
7.7.2	Business Continuity Management.....	7-2
Figure 7-5: Centralines' Business Continuity Management Programme		7-3

7-2 SECTION 7 RISK MANAGEMENT

7. RISK MANAGEMENT

7.7 Emergency Response and Contingency Plans

7.7.2 *Business Continuity Management*

Business Continuity Management is a process that identifies potential threats to the organisation as well as the impacts of those threats on business operations. It provides a framework for building organisational resilience and includes response capability to safeguard the interests of Centralines' key stakeholders, reputation, brand and value-creating activities.


During the 2015 financial year, a comprehensive organisational resilience review was completed by Centralines' Management Services Provider, Unison Networks Limited. As a result of this review, key projects to enhance organisational resilience have been initiated. Since Unison provides essential network management services to Centralines, improved network resilience during a major event will benefit Centralines directly. Progress on these major projects is detailed below.

- In June 2016, the containerised data centre went fully operational. The containerised data centre is elevated from the ground and placed on base isolators to provide increased resilience to significant seismic shaking and liquefaction. The data centre is external to the administration building to maintain operations in the event access to the main administration building is inaccessible.
- In December 2016, the purpose built "hot site" for the alternate operations centre, crisis management team and business critical recovery functions was completed. The "hot site" is strategically located in Havelock North where there is a lower risk of liquefaction, tsunami and flood hazards, than the previous alternate operations centre at Eastbourne Street, Hastings. The "hot site" includes N-1 fibre capability and is built to 100% of Importance Level 4 under the building standard.
- An upgraded 'Disaster Recovery' (DR) container will be located at the "hot site" in Havelock North is on track for completion in March 2017.

The physical attributes that provide an organisationally resilient system are underpinned by a number of continuity plans which Centralines' Management Services Provider has put in place to guide an effective and efficient response and recovery, should an event materialise.

These plans are detailed in Figure 7-5.

SECTION 7 RISK MANAGEMENT 7-3



7.7.2.1 Crisis Management Plan

The Crisis Management Plan is a key document in the Business Continuity Management Programme. Under the Management Services Agreement, Centralines is included in Unison's Crisis Management Plan. This provides Centralines with a framework to effectively manage any crisis event. It is focused on time-limited, problem-solving interventions to respond to crisis situations and to facilitate the restoration of core services. The success of the plan is dependent on clearly assigned and understood roles, responsibilities and delegations, as well as escalation procedures and coordinated response activities.

SECTION 8 EVALUATION OF PERFORMANCE

SECTION 8 EVALUATION OF PERFORMANCE 8-1

CONTENTS

8.	EVALUATION OF PERFORMANCE.....	8-2
8.1	Introduction to this Section	8-2
8.2	Review of Progress Against Plan	8-2
8.2.2	Physical Progress of Planned Capital Projects – 2015/16 (carryover)	8-2
8.2.3	Physical Progress of Planned Renewal Projects – 2016/17	8-3
8.2.5	Financial Progress 2015/16.....	8-4
8.2.6	Financial Progress 2016/17.....	8-6
8.3	Review of Service Level Performance	8-7
8.3.2	Service Level Performance 2015/16	8-7
8.3.3	Service Level Performance 2016/17	8-8
8.5	Health and Safety Performance	8-10
8.5.4	Employee Safety	8-10
	Table 8-2: Physical Progress of Planned Capital Projects – 2015/16 (carryover)	8-2
	Table 8-3: Physical Progress of Planned Capital Projects – 2016/17	8-4
	Table 8-5: Financial Progress Opex and Capex 2015/16	8-5
	Table 8-6: Financial Progress Opex and Capex 2016/17	8-6
	Table 8-8: Service Level Performance 2015/16	8-8
	Table 8-9: Service Level Performance 2016/17	8-9

8-2 SECTION 8 EVALUATION OF PERFORMANCE

8. EVALUATION OF PERFORMANCE

8.1 Introduction to this Section

Section 8: Evaluation of Performance provides information to enable stakeholders to understand how well Centralines is performing as an asset management organisation. The key performance dimensions covered are: physical and financial progress against the plans set out in the last disclosed AMP, performance against service level targets, and assessment under the Asset Management Maturity Assessment Tool. It is intended that the sections below will replace relevant sections of Section 8 in the 2016 AMP.

8.2 Review of Progress Against Plan

In this section Centralines' performance in delivering the plans set out in the AMP disclosed in March 2016 is reviewed in terms of physical progress (commissioning of works) and financial progress (cost performance). This evaluation is undertaken for the 2015/16 and 2016/17 financial years, for both capital and maintenance programmes.

8.2.2 Physical Progress of Planned Capital Projects – 2015/16 (carryover)

Project	Category	Status	Comments
Takapau Substation – Removal of 11kV Overhead Structure	Asset Replacement and Renewal	Complete	
Wilder Road 33kV Feeder Upgrade (Phases 3 to 5)	Asset Replacement and Renewal	Complete	

Table 8-2: Physical Progress of Planned Capital Projects – 2015/16 (carryover)

SECTION 8 EVALUATION OF PERFORMANCE 8-3

8.2.3 Physical Progress of Planned Renewal Projects – 2016/17

Ref	Project	Category	Status	Planned Spend (\$'000s)	Actual Spend (\$'000s)	Comments
39808	Wilder Road Stage 5	Asset Replacement and Renewal	In Design	150	30	Will carry over due to diversion of resources to customer work.
39810	Install new 33kV ripple CB at Waipukurau Zone Substation	Reliability, Safety and Environment	WIP	120	NA	On track for completion by 31 March 2017.
39802	Pole renewals Feeder 19	Asset Replacement and Renewal	Complete	100	98	On track for completion by 31 March 2017.
39807	Replace 2 pole mounted TX C4/6 with a 200kVA pad mount	Reliability, Safety and Environment	Complete	45	82	
39801	Pole renewals Feeder 4	Asset Replacement and Renewal	Complete	72	2	
39803	Pole renewals Feeder 91	Asset Replacement and Renewal	Complete	71	21	
39811	Seismic strengthening of the Waipawa Zone Substation	Reliability, Safety and Environment	Complete	54	NA	
39813	Takapau ZS REG-DA upgrade	Quality of Supply	Complete	50	NA	
39814	Waipukurau ZS REG-DA upgrade	Quality of Supply	Complete	50	NA	
39809	Feeder 13 - Install paralleling RCS on Pole 900757 to shift urban customers off Feeder 13 (rural) onto Feeder 15 (urban)	Quality of Supply	WIP	50	NA	On track for completion by 31 March 2017.
39804	Replace 2 pole mounted TX B4/16 with a new seismically	Reliability, Safety and Environment	Complete	42	47	

8-4 SECTION 8 EVALUATION OF PERFORMANCE

Ref	Project	Category	Status	Planned Spend (\$'000s)	Actual Spend (\$'000s)	Comments
	approved pole mounted transformer					
39800	Pole renewals Feeder 3	Asset Replacement and Renewal	Complete	30	15	
39805	Reconductor Awahiwi Road	Asset Replacement and Renewal	WIP	30	NA	On track for completion by 31 March 2017.
39806	Reconductor Settlement Road	Asset Replacement and Renewal	Complete	22	18	

Table 8-3: Physical Progress of Planned Capital Projects – 2016/17

8.2.5 Financial Progress 2015/16

Spend Category	Forecasted Expenditure from 2015/16 AMP (\$'000s)	Actual Expenditure (\$'000s)	Variance %	Explanation of Variances (+/-10%)
Consumer Connection	300	404	35%	The Customer Contributions overspend was due to an increased demand for customer connections.
System Growth	430	370	-14%	Initial project budgets were over-estimated.
Asset Replacement and Renewal	1,600	972	-40%	Pole inspections identified less pole replacements than anticipated.
Asset Relocations	120	103	-14%	There were less than anticipated assets requiring relocation during the 2015/2016 financial year.
Reliability, Safety and Environment	440	439	-0%	
Network Capex	2,890	2,288	-21%	

SECTION 8 EVALUATION OF PERFORMANCE 8-5

Maintenance Category	Forecasted Expenditure from 2015/16 AMP (\$'000s)	Actual Expenditure (\$'000s)	Variance %	Explanation of variances (+/-10%)
Service Interruptions and Emergencies	272	271	0%	
Vegetation Management	555	483	-13%	Expenditure was less than forecast as the use of external contractors was less than expected.
Routine and Corrective Maintenance and Inspections	195	107	-45%	Efficiencies including use of aerial surveys resulted in a significant underspend.
Asset Replacement and Renewal	399	452	13%	Budgets were stretched due to both of the main feeder jobs being located out at the coast. This resulted in a higher than anticipated cost of travel and also lost production time. Also, a lot more defect work was completed than anticipated. Both of these factors, resulted in actual expenditure being higher for Asset Replacement and Renewal than forecast.
Network Maintenance	1,421	1,313	-4%	

Table 8-5: Financial Progress Opex and Capex 2015/16

8-6 SECTION 8 EVALUATION OF PERFORMANCE

8.2.6 Financial Progress 2016/17

Spend Category	Forecasted Expenditure from 2015/16 AMP (\$'000s)	Forecasted Expenditure (\$'000s)	Variance %	Explanation of variances (+/-10%)
Consumer Connection	300	500	67%	Higher than anticipated customer connections.
System Growth	10	0	-100%	Minimal power quality issues raised or identified during the year.
Asset Replacement and Renewal	802	720	-10%	Some of Wilder Road expected to carryover (-\$120k). Pole replacements lower than budgeted (-\$164k). Unplanned and reactive spend lower than expected (-\$120k). Offset by transfer of RSE projects transferred (+\$365k refer below).
Asset Relocations	110	43	-61%	Lower than anticipated customer requests.
Reliability, Safety and Environment	490	119	-76%	\$365k of projects re-categorised as Asset Replacement and Renewal.
Network Capex	1,712	1,382	-19%	
Maintenance Category	Forecasted Expenditure from 2015/16 AMP (\$'000s)	Forecasted Expenditure (\$'000s)	Variance %	Explanation of variances (+/-10%)
Service Interruptions and Emergencies	258	336	30%	Higher than planned spend on first response activities.
Vegetation Management	512	517	1%	
Routine and Corrective Maintenance and Inspections	188	109	-42%	Ongoing efficiencies in inspection process resulting in decreased spend.
Asset Replacement and Renewal	465	431	-7%	
Network Maintenance	1,423	1,393	-2%	

Table 8-6: Financial Progress Opex and Capex 2016/17

SECTION 8 EVALUATION OF PERFORMANCE 8-7

8.3 Review of Service Level Performance

The Service Level framework changed for the 2015/16 financial year, corresponding to the start of the new regulatory period and implementation of new Asset Management Objectives.

8.3.2 Service Level Performance 2015/16

Table 8-8 shows current service level framework with targets as per Section 3 and actuals/forecasts for 2015/16 where available for year-end.

Asset Management Objective	Service Level	Unit/Type	Target 2015/16	Forecast 2015/16	Actual 2015/16	Comments
Health and Safety Performance	Accidents causing harm to a member of the public	Number of accidents	0	0	0	Service Level Target Met
	Serious harm or lost-time injury to employees or contractors	Number of injuries	0	0	1	Service Level Target Not Met
	Injuries to employees or contractors requiring medical treatment	Number of injuries	< 2	0	1	Service Level Target Met
Customer Service Performance	Surveyed customer satisfaction with delivery of customer works	%	> 95%	> 95%	100%	Service Level Target Met
	Average annual number of minutes a customer is without supply (SAIDI)	Minutes	98.80 – 119.07	71.38	72.67	Service Level Target Met & Exceeded
	Average annual number of supply interruptions a customer experiences (SAIFI)	Interruptions	2.84 – 3.52	1.4	1.4	Service Level Target Met & Exceeded
	Revenue per ICP	\$ (nominal)	\$1,588	\$1,588	\$1,522	Service Level Target Not Met
		Urban	≤ 20 events ≥ 3 hours	< 20	0	Service Level Target Met

8-8 SECTION 8 EVALUATION OF PERFORMANCE

Asset Management Objective	Service Level	Unit/Type	Target 2015/16	Forecast 2015/16	Actual 2015/16	Comments
	Restoration of Supply for unplanned interruptions	Rural	≤ 10 events ≥ 6 hours	< 10	1	Service Level Target Met
		Remote rural	≤ 5 events ≥ 12 hours	< 5	0	Service Level Target Met
Cost and Efficiency Performance	Forward work planning at a project level provided to contracting services providers	Years	≥ 1	1 year	1 year	Service Level Target Met
	Operating expenditure per ICP (nominal)	\$ (nominal)	$< \$444$	\$403	\$385	Service Level Target Met
	Faults per 100km of network	Total	< 6.2	NA	5.26	Service Level Target Met
		Overhead	< 7.6	NA	5.31	Service Level Target Met
		Underground	< 7.4	NA	3.11	Service Level Target Met

Table 8-8: Service Level Performance 2015/16

8.3.3 Service Level Performance 2016/17

Table 8-9 shows current service level framework with targets as per Section 3 and actuals/forecasts for 2016/17 where available for year-end.

Asset Management Objective	Service Level	Unit/Type	Target 2016/17	Forecast 2016/17	Comments
Health and Safety Performance	Accidents causing harm to a member of the public	Number of accidents	0	0	On Target
	Serious harm or lost-time injury to employees or contractors	Number of injuries	0	2	Service Level Target Not Met
	Injuries to employees or contractors requiring medical treatment	Number of injuries	< 2	1	On Target

SECTION 8 EVALUATION OF PERFORMANCE 8-9

Asset Management Objective	Service Level	Unit/Type	Target 2016/17	Forecast 2016/17	Comments
Customer Service Performance	Surveyed customer satisfaction with delivery of customer works	%	> 95%	> 95%	On Target
	Average annual number of minutes a customer is without supply (SAIDI)	Minutes	98.80 – 119.07	96.7	On Target to Meet and Exceed
	Average annual number of supply interruptions a customer experiences (SAIFI)	Interruptions	2.84 – 3.52	1.73	On Target to Meet and Exceed
	Revenue per ICP	\$ (nominal)	\$1,690	\$1,562	Service Level Unlikely to be Met
	Restoration of Supply for unplanned interruptions	Urban	<20	0	On Target
		Rural	<10	4	On Target
		Remote rural	<5	0	On Target
Cost and Efficiency Performance	Forward work planning at a project level provided to contracting services providers	Years	≥2 years rolling	2 years	On Target
	Operating expenditure per ICP (nominal)	\$ (nominal)	<\$447	\$422	On Target
	Faults per 100km of network	Total	<6.2	7.00	Service Level not Met
		Overhead	<7.6	7.08	On Target
		Underground	< 7.4	3.42	On Target

Table 8-9: Service Level Performance 2016/17

8-10 SECTION 8 EVALUATION OF PERFORMANCE

8.5 Health and Safety Performance

8.5.4 *Employee Safety*

8.5.4.1 *Employee Safety Performance*

Lost time injuries is the only Health and Safety service level objective that is forecasted not to be met for 2016/17.

The lost-time injury was a knee strain sustained by an employee in October 2016. This was as a result of an employee stepping backwards into a hole when tensioning a rope. Staff have been reminded of the need to do a thorough 360° check that not only includes vehicles but also the worksite and surrounding areas.

Additionally, while lost time and medical treatment injuries were forecasted to be at zero for 2015/16, one late lost time injury and one late medical treatment injury occurred in February 2016. Both of these were related to a truck tip over. One employee received a blow to the head and one injured his hip. As a result of this incident, level two and three driver training programmes will be completed over the next two years. Four-wheel drive truck training for all field staff will be completed when an appropriate course can be identified and scheduled.

SECTION 9 CAPABILITY TO DELIVER



SECTION 9 CAPABILITY TO DELIVER 9-1

NO MATERIAL CHANGES

SECTION 10 SCHEDULES

SECTION 10 SCHEDULES 10-1

CONTENTS

10.	SCHEDULES	10-2
11a	Report on Forecast Capital Expenditure	10-2
11b	Report on Forecast Operational Expenditure	10-10
12a	Report on Asset Condition.....	10-12
12b	Report on Forecast Capacity.....	10-14
12c	Report on Forecast Network Demand.....	10-16
12d	Report on Forecast Interruptions and Duration	10-18
13	No Material Changes	

This schedule requires a breakdown of forecast expenditure on assets for the current disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms. Also required is a forecast of the value of commissioned assets (i.e., the value of RAB additions)

This information is not part of audited disclosure information.

© Centralines Limited 2017

SECTION 10 SCHEDULES 10-3

CY+3 31 Mar 20	CY+4 31 Mar 21	CY+5 31 Mar 22	CY+6 31 Mar 23	CY+7 31 Mar 24	CY+8 31 Mar 25	CY+9 31 Mar 26	CY+10 31 Mar 27
321	327	333	339	345	351	357	363
-	-	-	-	-	-	-	-
948	884	817	1,346	1,312	1,335	929	945
54	55	56	124	127	129	131	133
536	633	845	351	299	785	310	315
21	22	22	23	-	-	-	-
445	357	378	272	334	310	363	321
1,002	1,012	1,245	645	633	1,095	673	636
2,325	2,278	2,450	2,455	2,418	2,911	2,091	2,077
520	464	361	300	606	580	161	164
2,844	2,742	2,812	2,755	3,023	3,490	2,252	2,241

-	-	-	-	-	-	-	-
321	327	333	339	345	351	357	363
-	-	-	-	-	-	-	-

2,523	2,415	2,478	2,415	2,678	3,139	1,894	1,878
--------------	--------------	--------------	--------------	--------------	--------------	--------------	--------------

--	--	--	--	--	--	--	--

300	300	300	300	300	300	300	300
-	-	-	-	-	-	-	-
885	810	735	1,190	1,140	1,140	780	780
50	50	50	110	110	110	110	110
500	580	760	310	260	670	260	260
20	20	20	20	-	-	-	-
415	328	340	240	290	265	305	265
935	928	1,120	570	550	935	565	525
2,170	2,088	2,205	2,170	2,100	2,485	1,755	1,715
485	425	325	265	526	495	135	135
2,655	2,513	2,530	2,435	2,626	2,980	1,890	1,850

50	50	50	50	50	50	50	50
----	----	----	----	----	----	----	----

10-4 SECTION 10 SCHEDULES

	Current Year 31 Mar 17	CY+1 31 Mar 18	CY+2 31 Mar 19
<i>for year ended</i>			
Difference between nominal and constant price forecasts	\$000		
Consumer connection	-	7	15
System growth	-	1	-
Asset replacement and renewal	-	23	45
Asset relocations	-	1	2
Reliability, safety and environment:			
Quality of supply	-	11	10
Legislative and regulatory	-	2	3
Other reliability, safety and environment	-	9	34
Total reliability, safety and environment	-	22	48
Expenditure on network assets	-	54	111
Non-network assets	-	26	13
Expenditure on assets	-	81	124

11a(ii): Consumer Connection

	Current Year 31 Mar 17	CY+1 31 Mar 18	CY+2 31 Mar 19
<i>for year ended</i>			
Consumer types defined by EDB*	\$000 (in constant prices)		
Simple	500	293	300
Consumer connection expenditure	500	293	300
<i>less</i> Capital contributions funding consumer connection	305	266	300
Consumer connection less capital contributions	195	26	-

11a(iii): System Growth

Sub-transmission	-	-
Zone substations	-	-
Distribution and LV lines	39	-
Distribution and LV cables	-	-
Distribution substations and transformers	-	-
Distribution switchgear	-	-
Other network assets	-	-
System growth expenditure	-	39
<i>less</i> Capital contributions funding system growth		
System growth less capital contributions	-	39

11a(iv): Asset Replacement and Renewal

Sub-transmission	29	-	-
Zone substations	216	-	-
Distribution and LV lines	327	864	810
Distribution and LV cables	5	-	-
Distribution substations and transformers	141	63	-
Distribution switchgear	2	-	100
Other network assets	-	-	-
Asset replacement and renewal expenditure	720	927	910
<i>less</i> Capital contributions funding asset replacement and renewal	-	-	-
Asset replacement and renewal less capital contributions	720	927	910

SECTION 10 SCHEDULES 10-5

CY+3 31 Mar 20	CY+4 31 Mar 21	CY+5 31 Mar 22	CY+6 31 Mar 23	CY+7 31 Mar 24	CY+8 31 Mar 25	CY+9 31 Mar 26	CY+10 31 Mar 27
21	27	33	39	45	51	57	63
-	-	-	-	-	-	-	-
63	74	82	156	172	195	149	165
4	5	6	14	17	19	21	23
36	53	85	41	39	115	50	55
1	2	2	3	-	-	-	-
30	30	38	32	44	45	58	56
67	85	125	75	83	160	108	111
155	191	245	285	318	426	336	362
35	39	36	35	80	85	26	29
189	229	282	320	397	510	362	391

CY+3 31 Mar 20	CY+4 31 Mar 21	CY+5 31 Mar 22
300	300	300
300	300	300
300	300	300
-	-	-

-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-

-	-	-	-	-	-	-	-
-	-	-	500	450	450	-	-
830	755	680	680	680	680	680	680
-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-
55	55	55	10	10	10	100	100
-	-	-	-	-	-	-	-
885	810	735	1,190	1,140	1,140	780	780
-	-	-	-	-	-	-	-
885	810	735	-	-	-	-	-

10-6 SECTION 10 SCHEDULES

11a(v): Asset Relocations

	<i>for year end</i>	<i>Current Year</i>	<i>CY+1</i>	<i>CY+2</i>
		31 Mar 17	31 Mar 18	31 Mar 19
<i>Project or programme*</i>		\$000 (in constant prices)		
Distribution and LV cables		27	20	20
Distribution substations and transformers		11	20	20
Distribution switchgear		5	10	10
All other asset relocations projects or programmes		-	-	-
Asset relocations expenditure		43	49	50
<i>less</i> Capital contributions funding asset relocations		-	-	-
Asset relocations less capital contributions		43	49	50

11a(vi): Quality of Supply

	<i>for year end</i>	<i>Current Year</i>	<i>CY+1</i>	<i>CY+2</i>
		31 Mar 17	31 Mar 18	31 Mar 19
<i>Project or programme*</i>		\$000 (in constant prices)		
Subtransmission		-	-	-
Zone substations		-	-	-
Distribution and LV lines		-	10	10
Distribution and LV cables		-	-	-
Distribution substations and transformers		-	107	-
Distribution switchgear		-	283	200
Other network assets		-	44	-
All other quality of supply projects or programmes		-	-	-
Quality of supply expenditure		-	444	210
<i>less</i> Capital contributions funding quality of supply		-	-	-
Quality of supply less capital contributions		-	444	210

11a(vii): Legislative and Regulatory

<i>Project or programme*</i>				
Subtransmission		-	-	-
Zone substations		-	98	55
Distribution and LV lines		-	-	-
Distribution and LV cables		-	-	-
Distribution substations and transformers		-	-	-
Distribution switchgear		-	-	-
Other network assets		-	-	-
All other legislative and regulatory projects or programmes		-	-	-
Legislative and regulatory expenditure		-	98	55
<i>less</i> Capital contributions funding legislative and regulatory		-	-	-
Legislative and regulatory less capital contributions		-	98	55

SECTION 10 SCHEDULES 10-7

CY+3 31 Mar 20	CY+4 31 Mar 21	CY+5 31 Mar 22
20	20	20
20	20	20
10	10	10

-	-	-
50	50	50
-	-	-
50	50	50

CY+3 31 Mar 20	CY+4 31 Mar 21	CY+5 31 Mar 22	CY+6 31 Mar 23	CY+7 31 Mar 24	CY+8 31 Mar 25	CY+9 31 Mar 26	CY+10 31 Mar 27
-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-
10	370	310	260	10	670	10	260
-	-	-	-	-	-	-	-
280	-	250	-	250	-	250	-
210	210	200	50	-	-	-	-
-	-	-	-	-	-	-	-

-	-	-					
500	580	760	310	260	670	260	260
-	-	-					
500	580	760					

-	-	-	-	-	-	-	-
20	20	20	20	-	-	-	-
-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-

-	-	-					
20	20	20	20	-	-	-	-
-	-	-					
20	20	20					

10-8 SECTION 10 SCHEDULES

11a(viii): Other Reliability, Safety and Environment		Current Year	CY+1	CY+2
		31 Mar 17	31 Mar 18	31 Mar 19
<i>Project or programme*</i>		\$000 (in constant prices)		
Subtransmission		-	-	-
Zone substations		65	122	525
Distribution and LV lines		-	137	20
Distribution and LV cables		-	-	-
Distribution substations and transformers		-	98	145
Distribution switchgear		54	-	-
Other network assets		-	-	-
All other reliability, safety and environment projects or programmes		-	-	-
Other reliability, safety and environment expenditure		119	356	690
<i>less</i> Capital contributions funding other reliability, safety and environment		-	-	-
Other reliability, safety and environment less capital contributions		119	356	690
11a(ix): Non-Network Assets				
		Current Year	CY+1	CY+2
		31 Mar 17	31 Mar 18	31 Mar 19
Routine expenditure				
<i>Project or programme*</i>		\$000 (in constant prices)		
Motor Vehicles		56	118	215
Plant, Equipment and Tools		116	239	40
Information Technology		-	-	-
Office Equipment		10	115	15
Land and Buildings		-	4	-
All other routine expenditure projects or programmes		-	-	-
Routine expenditure		182	476	270
Atypical expenditure				
<i>Project or programme*</i>				
Seismic strengthening of Waipukurau Substation building		-	98	-
Office building upgrades		-	488	-
All other atypical projects or programmes		-	-	-
Atypical expenditure		-	586	-
Non-network assets expenditure		182	1,062	270

SECTION 10 SCHEDULES 10-9

CY+3 31 Mar 20	CY+4 31 Mar 21	CY+5 31 Mar 22	CY+6 31 Mar 23	CY+7 31 Mar 24	CY+8 31 Mar 25	CY+9 31 Mar 26	CY+10 31 Mar 27
-	-	-	-	-	-	-	-
100	38	275	25	25	-	40	-
20	20	20	20	20	20	20	20
-	-	-	-	-	-	-	-
45	45	45	45	45	45	45	45
-	-	-	150	200	200	200	200
250	225	-	-	-	-	-	-

-	-	-					
415	328	340	240	290	265	305	265
-	-	-					
415	328	340					

CY+3 31 Mar 20	CY+4 31 Mar 21	CY+5 31 Mar 22
430	370	270
40	40	40
-	-	-
15	15	15
-	-	-

-	-	-
485	425	325

-	-	-
-	-	-

-	-	-
---	---	---

485	425	325
-----	-----	-----

10-10 SECTION 10 SCHEDULES

11b: Report on Forecast Operational Expenditure

This schedule requires a breakdown of forecast operational expenditure for the disclosure year and a 10 year planning period. The forecasts should be consistent with the supporting information set out in the AMP. The forecast is to be expressed in both constant price and nominal dollar terms.

EDBs must provide explanatory comment on the difference between constant price and nominal dollar operational expenditure forecasts in Schedule 14a (Mandatory Explanatory Notes).

This information is not part of audited disclosure information.

	Current Year 31 Mar 17	CY+1 31 Mar 18	CY+2 31 Mar 19
for year ended			
Operational Expenditure Forecast	\$000 (in nominal dollars)		
Service interruptions and emergencies	336	264	271
Vegetation management	517	473	433
Routine and corrective maintenance and inspection	109	193	198
Asset replacement and renewal	431	476	489
Network Opex	1,393	1,406	1,392
System operations and network support	234	238	250
Business support	1,933	1,918	2,016
Non-network Opex	2,167	2,156	2,267
Operational expenditure	3,560	3,562	3,659
	\$000 (in constant prices)		
Service interruptions and emergencies	336	257	258
Vegetation management	517	461	412
Routine and corrective maintenance and inspection	109	188	188
Asset replacement and renewal	431	464	465
Network Opex	1,393	1,371	1,323
System operations and network support	234	232	238
Business support	1,933	1,870	1,917
Non-network Opex	2,167	2,102	2,155
Operational expenditure	3,560	3,472	3,478
Subcomponents of operational expenditure (where known)			
Energy efficiency and demand side anagement, reduction of energy losses	-	-	-
Direct billing*	-	-	-
Research and Development	-	-	-
Insurance	-	-	-
<i>* Direct billing expenditure by suppliers that direct bill the majority of their consumers</i>			
Difference between nominal and real forecasts	\$000		
Service interruptions and emergencies	-	7	13
Vegetation management	-	12	21
Routine and corrective maintenance and inspection	-	5	10
Asset replacement and renewal	-	12	24
Network Opex	-	35	69
System operations and network support	-	6	12
Business support	-	48	99
Non-network Opex	-	54	112
Operational expenditure	-	90	181

SECTION 10 SCHEDULES 10-11

CY+3 31 Mar 20	CY+4 31 Mar 21	CY+5 31 Mar 22	CY+6 31 Mar 23	CY+7 31 Mar 24	CY+8 31 Mar 25	CY+9 31 Mar 26	CY+10 31 Mar 27
276	281	286	291	296	302	307	312
387	394	401	409	416	423	430	438
201	205	209	212	216	220	224	227
497	506	516	525	534	544	553	562
1,361	1,386	1,412	1,437	1,463	1,488	1,514	1,539
254	259	264	269	273	278	283	288
2,049	2,088	2,126	2,164	2,203	2,241	2,280	2,318
2,304	2,347	2,390	2,433	2,476	2,519	2,563	2,606
3,665	3,733	3,802	3,871	3,939	4,008	4,076	4,145

258	258	258	258	258	258	258	258
362	362	362	362	362	362	362	362
188	188	188	188	188	188	188	188
465	465	465	465	465	465	465	465
1,273	1,273	1,273	1,273	1,273	1,273	1,273	1,273
238	238	238	238	238	238	238	238
1,917	1,917	1,917	1,917	1,917	1,917	1,917	1,917
2,155	2,155	2,155	2,155	2,155	2,155	2,155	2,155
3,428	3,428	3,428	3,428	3,428	3,428	3,428	3,428

-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-

18	23	28	33	38	44	49	54
25	32	39	47	54	61	68	76
13	17	21	24	28	32	36	39
32	41	51	60	69	79	88	97
88	113	139	164	190	215	241	266
16	21	26	31	35	40	45	50
132	171	209	247	286	324	363	401
149	192	235	278	321	364	408	451
237	305	374	443	511	580	648	717

10-12 SECTION 10 SCHEDULES

12a: Report on Asset Condition

This schedule requires a breakdown of asset condition by asset class as at the start of the forecast year. The data accuracy assessment relates to the percentage values disclosed in the asset condition columns. Also required is a forecast of the percentage of units to be replaced in the next 5 years. All information should be consistent with the information provided in the AMP and the expenditure on assets forecast in Schedule 11a. All units relating to cable and line assets, that are expressed in km, refer to circuit lengths.

Voltage	Asset category	Asset class	Units
All	Overhead Line	Concrete poles / steel structure	No.
All	Overhead Line	Wood poles	No.
All	Overhead Line	Other pole types	No.
HV	Subtransmission Line	Subtransmission OH up to 66kV conductor	km
HV	Subtransmission Line	Subtransmission OH 110kV+ conductor	km
HV	Subtransmission Cable	Subtransmission UG up to 66kV (XLPE)	km
HV	Subtransmission Cable	Subtransmission UG up to 66kV (Oil pressurised)	km
HV	Subtransmission Cable	Subtransmission UG up to 66kV (Gas pressurised)	km
HV	Subtransmission Cable	Subtransmission UG up to 66kV (PILC)	km
HV	Subtransmission Cable	Subtransmission UG 110kV+ (XLPE)	km
HV	Subtransmission Cable	Subtransmission UG 110kV+ (Oil pressurised)	km
HV	Subtransmission Cable	Subtransmission UG 110kV+ (Gas Pressurised)	km
HV	Subtransmission Cable	Subtransmission UG 110kV+ (PILC)	km
HV	Subtransmission Cable	Subtransmission submarine cable	km
HV	Zone Substation Buildings	Zone substations up to 66kV	No.
HV	Zone Substation Buildings	Zone substations 110kV+	No.
HV	Zone Substation Switchgear	22/33kV CB (Indoor)	No.
HV	Zone Substation Switchgear	22/33kV CB (Outdoor)	No.
HV	Zone Substation Switchgear	33kV Switch (Ground Mounted)	No.
HV	Zone Substation Switchgear	33kV Switch (Pole Mounted)	No.
HV	Zone Substation Switchgear	33kV RMU	No.
HV	Zone Substation Switchgear	50/66/110kV CB (Indoor)	No.
HV	Zone Substation Switchgear	50/66/110kV CB (Outdoor)	No.
HV	Zone Substation Switchgear	3.3/6.6/11/22kV CB (ground mounted)	No.
HV	Zone Substation Switchgear	3.3/6.6/11/22kV CB (pole mounted)	No.
HV	Zone substation Transformer	Zone Substation Transformers	No.
HV	Distribution Line	Distribution OH Open Wire Conductor	km
HV	Distribution Line	Distribution OH Aerial Cable Conductor	km
HV	Distribution Line	SWER conductor	km
HV	Distribution Cable	Distribution UG XLPE or PVC	km
HV	Distribution Cable	Distribution UG PILC	km
HV	Distribution Cable	Distribution Submarine Cable	km
HV	Distribution Switchgear	3.3/6.6/11/22kV CB (pole mounted) - reclosers and sectionalisers	No.
HV	Distribution Switchgear	3.3/6.6/11/22kV CB (Indoor)	No.
HV	Distribution Switchgear	3.3/6.6/11/22kV Switches and fuses (pole mounted)	No.
HV	Distribution Switchgear	3.3/6.6/11/22kV Switch (ground mounted) - except RMU	No.
HV	Distribution Switchgear	3.3/6.6/11/22kV RMU	No.
HV	Distribution Transformer	Pole Mounted Transformer	No.
HV	Distribution Transformer	Ground Mounted Transformer	No.
HV	Distribution Transformer	Voltage regulators	No.
HV	Distribution Substations	Ground Mounted Substation Housing	No.
LV	LV Line	LV OH Conductor	km
LV	LV Cable	LV UG Cable	km
LV	LV Streetlighting	LV OH/UG Streetlight circuit	km
LV	Connections	OH/UG consumer service connections	No.
All	Protection	Protection relays (electromechanical, solid state and numeric)	No.
All	SCADA and communications	SCADA and communications equipment operating as a single system	Lot
All	Capacitor Banks	Capacitors including controls	No.
All	Load Control	Centralised plant	Lot
All	Load Control	Relays	No.
All	Civils	Cable Tunnels	km

SECTION 10 SCHEDULES 10-13

Asset condition at start of planning period (percentage of units by grade)							
Grade 1	Grade 2	Grade 3	Grade 4	Grade unknown	Data accuracy (1-4)	% of asset forecast to be replaced in next 5 years	
-	0.50%	66.50%	33.00%	-	3	1.00%	
	18.00%	76.00%	6.00%	-	3	20.00%	
-	-	-	-	-	N/A	-	
-	-	94.00%	6.00%	-	2	-	
-	-	-	-	-	N/A	-	
-	-	5.00%	95.00%	-	3	-	
-	-	-	-	-	N/A	-	
-	-	-	-	-	N/A	-	
-	-	-	-	-	N/A	-	
-	-	-	-	-	N/A	-	
-	-	-	-	-	N/A	-	
-	-	-	-	-	N/A	-	
-	-	-	-	-	N/A	-	
-	-	33.00%	67.00%	-	3	-	
-	-	-	-	-	N/A	-	
-	-	-	-	-	N/A	-	
-	-	-	100.00%	-	4	-	
-	-	-	-	-	N/A	-	
-	5.00%	40.00%	55.00%	-	3	-	
-	-	-	-	-	N/A	-	
-	-	-	-	-	N/A	-	
-	-	-	-	-	N/A	-	
-	-	67.00%	33.00%	-	3	-	
-	-	-	100.00%	-	3	-	
-	-	57.00%	43.00%	-	3	-	
	1.00%	95.00%	4.00%	-	2	1.00%	
-	-	-	-	-	N/A	-	
-	-	-	-	-	N/A	-	
-	-	5.00%	95.00%	-	3	0.50%	
-	-	5.00%	95.00%	-	3	0.50%	
-	-	-	-	-	N/A	-	
-	3.00%	45.00%	52.00%	-	3	5.00%	
-	-	-	-	-	N/A	-	
	1.00%	47.00%	52.00%	-	2	2.00%	
-	-	-	-	-	N/A	-	
-	5.00%	15.00%	80.00%	-	3	2.00%	
	1.00%	69.00%	30.00%	-	3	1.50%	
	1.00%	20.00%	79.00%	-	3	1.00%	
-	5.00%	10.00%	85.00%	-	3	2.00%	
-	-	-	100.00%	-	2	-	
	0.50%	89.50%	10.00%	-	2	0.50%	
-	-	27.00%	73.00%	-	2	0.50%	
-	-	27.00%	73.00%	-	2	0.50%	
0.15%	-	-	99.85%	-	2	0.50%	
-	-	33.33%	66.67%	-	2	5.00%	
-	-	-	100.00%	-	2	-	
-	-	-	100.00%	-	4	-	
-	-	-	100.00%	-	4	-	
-	-	100.00%	-	-	1	-	
-	-	-	-	-	N/A	-	

10-14 SECTION 10 SCHEDULES

12b: Report on Forecast Capacity

This schedule requires a breakdown of current and forecast capacity and utilisation for each zone substation and current distribution transformer capacity. The data provided should be consistent with the information provided in the AMP. Information provided in this table should relate to the operation of the network in its normal steady state configuration.

12b(i): System Growth - Zone Substations

Existing Zone Substations	Current Peak Load (MVA)	Installed Firm Capacity (MVA)	Security of Supply Classification (type)	Transfer Capacity (MVA)	Utilisation of Installed Firm Capacity %	
Waipukurau	8.0	10.0	N-1		80%	
Waipawa	4.0	7.5	N-1		53%	
Takapau	6.2	7.5	N-1		82%	
OngaOnga	6.1	-	N-1 Switched	10.0	-	
Wilder Road	1.2	-	N-1 Switched	2.4	-	

¹ Extend forecast capacity table as necessary to disclose all capacity by each zone substation

SECTION 10 SCHEDULES 10-15

	Installed Firm Capacity +5 years (MVA)	Utilisation of Installed Firm Capacity + 5yrs %	Installed Firm Capacity Constraint +5 years (cause)	Explanation
	10.0	80%	No constraint within +5 years	
	7.5	53%	No constraint within +5 years	
	7.5	82%	No constraint within +5 years	
	-	-	No constraint within +5 years	Load transfer from adjacent substations available using remote switches.
	-	-	No constraint within +5 years	Load transfer from adjacent substations available using remote switches.

10-16 SECTION 10 SCHEDULES

12c: Report on Forecast Network Demand

This schedule requires a forecast of new connections (by consumer type), peak demand and energy volumes for the disclosure year and a 5 year planning period. The forecasts should be consistent with the supporting information set out in the AMP as well as the assumptions used in developing the expenditure forecasts in Schedule 11a and Schedule 11b and the capacity and utilisation forecasts in Schedule 12b.

12c(i): Consumer Connections

Number of ICPs connected in year by consumer type

	for year ended	Current Year 31 Mar 17	CY+1 31 Mar 18
Consumer types defined by EDB*		Number of connections	
Small Customers		8323	8343
Medium Customers		176	177
Large Customers		2	2
Connections total		8,501	8,522

**include additional rows if needed*

Distributed generation

Number of connections	-	-
Installed connection capacity of distributed generation (MVA)	-	-

12c(ii) System Demand

Maximum coincident system demand (MW)	for year ended	Number of connections	
GXP demand		21	21
plus Distributed generation output at HV and above		-	-
Maximum coincident system demand		21	21
less Net transfers to (from) other EDBs at HV and above		-	-
Demand on system for supply to consumers' connection points		21	21
Electricity volumes carried (GWh)			
Electricity supplied from GXPs		112	112
less Electricity exports to GXPs		-	-
plus Electricity supplied from distributed generation		-	-
less Net electricity supplied to (from) other EDBs		-	-
Electricity entering system for supply to ICPs		112	112
less Total energy delivered to ICPs		103	103
Losses		9	9
Load factor		61%	61%
Loss ratio		8.0%	8.0%

SECTION 10 SCHEDULES 10-17

CY+2 31 Mar 19	CY+3 31 Mar 20	CY+4 31 Mar 21	CY+5 31 Mar 22
Number of connections			
8363	8383	8403	8423
178	179	180	181
2	2	2	2
8,543	8,564	8,585	8,606

-	-	-	-
-	-	-	-

Number of connections			
21	21	22	22
-	-	-	-
21	21	22	22
-	-	-	-
21	21	22	22

112	112	112	112
-	-	-	-
-	-	-	-
-	-	-	-
112	112	112	112
103	103	103	103
9	9	9	9

61%	60%	59%	59%
8.0%	8.0%	8.0%	8.0%

10-18 SECTION 10 SCHEDULES

12d: Report Forecast Interruptions and Duration

This schedule requires a forecast of SAIFI and SAIDI for disclosure and a 5 year planning period. The forecasts should be consistent with the supporting information set out in the AMP as well as the assumed impact of planned and unplanned SAIFI and SAIDI on the expenditures forecast provided in Schedule 11a and Schedule 11b.

	<i>Current Year</i>	<i>CY+1</i>	<i>CY+2</i>	<i>CY+3</i>	<i>CY+4</i>	<i>CY+5</i>
for year ended	31 Mar 17	31 Mar 18	31 Mar 19	31 Mar 20	31 Mar 21	31 Mar 22
SAIDI						
Class B (planned interruptions on the network)	78.5	72.7	72.7	72.7	72.7	72.7
Class C (unplanned interruptions on the network)	60.2	82.7	82.7	82.7	82.7	82.7
SAIFI						
Class B (planned interruptions on the network)	0.36	0.46	0.46	0.46	0.46	0.46
Class C (unplanned interruptions on the network)	1.56	3.29	3.29	3.29	3.29	3.29



CERTIFICATION FOR YEAR-BEGINNING DISCLOSURES

Pursuant to Schedule 17


We, Jon Edmond Nichols and Nicholas Matthew Story, being directors of Centralines Limited certify that, having made all reasonable enquiry, to the best of our knowledge:

- a) The following attached information of Centralines Limited prepared for the purposes of clauses 2.4.1, 2.6.1, 2.6.3, 2.6.6 and 2.7.2 of the Electricity Distribution Information Disclosure Determination 2012 in all material respects complies with that determination.
- b) The prospective financial or non-financial information included in the attached information has been measured on a basis consistent with regulatory requirements or recognised industry standards.
- c) The forecasts in Schedules 11a, 11b, 12a, 12b, 12c and 12d are based on objective and reasonable assumptions which both align with Centralines Limited's corporate vision and strategy and are documented in retained records.



Director

Date: 29th March 2017



Director

Date: 29th March 2017

CENTRALINES LIMITED

P0 Box 59, Waipukurau Telephone (06) 858 7770 Fax (06) 858 6601

www.centralines.co.nz